



Bluelight Software

902 Redwood Drive
Loveland, CO 80538

Phone: 970-461-8554

Fax: 970-461-8555

NFPA Member
Permit #93989593
www.bluelightsw.com

www.efinitymobile.com
sales@bluelightsw.com
support@bluelightsw.com

Versatile Data Collection, Dynamic Forms Building
Providing software solutions to service industries for decades

CLEAN AGENT INSPECTION

Customer Address:

Bluelight Software, LLC
902 Redwood Drive
Loveland, CO 80538
Phone: (970) 461-8554
Fax: (970) 461-8555

Customer #: 111

Contract #: 5544

Job Status: Archived

Job Name: Clean Agent Sample Report

Site Address:

Bluelight Software, LLC
902 Redwood Drive
Loveland, CO 80538
Phone: (970) 461-8554
Fax: (970) 461-8555

Contact: Al Riggs

Site #: 756

Inspection Date: 2/12/2007

GAS TYPE	AGENT STORAGE CONTAINER TYPE	SERIAL #	PRESSURE	WEIGHT	TEMP.
CO2	AMEREX CORP.		100	45	71
Eccard-25	PYRO CHEM		2000	75	71

DETECTOR RESPONSE AND MANUAL PULL STATION TESTS

	TYPE	QTY.	CHECKED
Ionization Detectors	AMES CO	4	Yes
Photoelectric Detectors	ASCOA FIRE SYSTEMS	1	Yes
Thermal Detectors	CEASE FIRE CORP.	3	Yes

Manual Pull Stations	CONBRACO	4	Yes
Aborts	FAIRBANKS MORSE	7	Yes
Control Head/Initiator	ASCOA FIRE SYSTEMS	4	Yes
Pressure Operated Switch	CERBERUS PYROTRONICS	2	Yes
Main/Reserve Switch	CERBERUS PYROTRONICS	3	Yes
Horns	ANGUS FIRE ARMOUR	1	Yes
Strobes	ASCOA FIRE SYSTEMS	2	Yes
Speakers/Strobes	FIRETROL	1	Yes
Bells	STRIKE FIRE	3	Yes
Remote Annunciator	FLAG FIRE	1	Yes
Battery Standby Test (vdc) - 4500 (amps) - 20000	FAIRBANKS MORSE	2	Yes
System Control Unit	AMEREX CORP.	4	Yes

SYSTEM FUNCTIONS

A.H.U.	Yes
E.P.O.	Yes
Remote Alarm Signal	Yes
Correct Signage	No
Comments: Need signage	
Tag Color : Green tag	

Jim Beam

11/1/2006

Customer: Jim Beam

Sam Adams

11/1/2006

Inspection Technician: Sam Adams