



Bluelight Software

902 Redwood Drive
Loveland, CO 80538

Phone: 970-461-8554

Fax: 970-461-8555

NFPA Member
Permit #93989593
www.bluelightsw.com

www.efinitymobile.com
sales@bluelightsw.com
support@bluelightsw.com

Versatile Data Collection, Dynamic Forms Building
Providing software solutions to service industries for decades

KITCHEN EXHAUST HOOD FIRE SUPPRESSION SYSTEM INSPECTION

Customer Address:

Bluelight Software, LLC
902 Redwood Drive
Loveland, CO 80538
Phone: (970) 461-8554
Fax: (970) 461-8555

Customer #: 111

Contract #: 567

Job Status: Archived

Job Name: Rangehood Form Sample Report

Site Address:

Bluelight Software, LLC
902 Redwood Drive
Loveland, CO 80538
Phone: (970) 461-8554
Fax: (970) 461-8555

Contact: Al Riggs

Site #: 443

Inspection Date: 2/12/2007

SYSTEM MFG.	AMES CO	MODEL NUMBER	347355
CYLINDER SIZE	50 lb.	CYLINDER TYPE	Dry Chemical

DETECTION

- Yes Manual pull station tested _____
- Yes Tested good (terminal link cut) _____
- Yes Fusible links replaced _____
- Yes Quartzoid links cleaned _____
- Yes Conduit & piping properly secured _____

NOZZLES

- No Duct & plenum covered with correct nozzles Incorrect nozzles on duct _____
- Yes Properly positioned over all appliances with correct nozzles _____
- Yes Covers/seals in place, clear of obstructions _____

FUEL SHUT-OFF

- Yes Gas valve working properly Solenoid _____
- Yes Electrical shut-off working properly _____
- Yes Reset breakers _____
- Yes Re-lit pilot lights _____

AGENT CYLINDERS

- Yes Pressure gauge in operable range _____
- Yes Cartridge weight verified _____
- Yes Date of last 6 yr. maintenance _____
- Yes Date of last 12 yr. hydrotest _____
- Yes Piping & conduit securely bracketed _____
- Yes Manual & remote set/seals in place _____
- Yes System operational and seals in place _____

APPLIANCES

- Yes Proper separation between fryers & flame _____
- Yes Proper clearance from flame to filters _____
- Yes Exhaust fan operating _____
- Yes All filters in place _____
- Yes No class "A" materials under hood _____

CONDITION OF HOOD Very Clean _____

PORTABLE EXTINGUISHERS

- Yes Hand portable extinguisher of proper type mounted on walls _____
- Yes Required service performed _____

HOOD SIZE 36"

COOKING APPLIANCES (Left to Right)

	Description	Size	Gas	Electric
1)	6-Burner	48"	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2)	Tilt Skillet	12"	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3)	8-Burner	64"	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4)	Charbroiler	24"	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5)	6-Burner	36"	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6)	4-Burner	24"	<input type="checkbox"/>	<input checked="" type="checkbox"/>
7)	Tilt Skillet Griddle	12"	<input type="checkbox"/>	<input checked="" type="checkbox"/>

The above system has been tested and inspected in accordance with manufacturer's specifications and is found to comply with all current fire codes except the following:

Incorrect nozzles on duct



2/13/2007

Customer: Jim Beam



2/13/2007

Inspection Technician: Sam Adams